

Northern Nevada Steering committee meeting

Minutes for the meeting of Tuesday, March 22, 2011

Mike McCullogh, NNICC Northern Nevada Steering Committee Chairman, called the meeting to order and determined a quorum was present. Steering Committee members present: Mike McCullogh, NNICC; Mark Meranda, City of Sparks; Don Jeppson, Washoe County; Nick Malarchik, Lyon County; Ky Karlson, ABC; Sheena Beaver, BAWN; Dee Stueve, AGC; Robb Wong, BANN; Jess Traver, BANN

(1) Approved February 22nd meeting notes.

(2) Consider Southern Nevada amendments to the 2009 IECC

The committee is reviewing the Southern Nevada 2009 IECC Amendments to consider using some of their amendments as modifications to the Northern Nevada amendments to the 2009 IECC. The Southern Nevada Amendments have been approved by Renewable Energy and Energy Efficiency Authority. (Continued from last meeting)

Southern Nevada Amendments (SNA) sections;

Definitions;

Casino	Passed	Unanimous
Casino gaming area	Passed	Unanimous
Conditioned space	Passed	Unanimous as amended using ASREA's definitions .
Insulation (Thermal)	Failed	Unanimous
Occupant sensors (lighting)	Passed	2-Against/6-For as amended without the last sentence.
303.1.3 Fenestration product rating	Passed	1-Against/7-For as amended
303.1.3.1 & 303.1.3.2 Construction site rating documentation	Passed	Unanimous as amended
401.3 Certificate	Passed	Unanimous as amended
403.2.2 Sealing (Mandatory)	Failed	Unanimous
403.4.1 Non circulating hot water systems	Failed	Unanimous

403.5 (exemption)	Failed	Unanimous
403.6 Equipment sizing (Mandatory)	Passed	Unanimous
403.6.1 Minimum capabilities, Item 2	Passed	Unanimous
502.4.5 Outdoor air intake and exhaust opening, exceptions 2 thru 6	Tabled	Research motorized vs. gravity dampers.
503.2.5.1 Demand of controlled ventilation	Tabled	Research 2006/2009 UMC Table 4-1
505.2.1 Interior lighting controls	Passed	Unanimous
505.2.2 Additional controls	Passed	Unanimous
505.2.3 Daylight zone control, exceptions 2 and 3	Passed	Unanimous
505.5.1 Total connected interior power, exceptions 7 and 15	Passed	Unanimous
505.6.2 Exterior building lighting power, exceptions 2 and 8	Passed	Unanimous
Chapter 6 reference standards to include the organization ACCA table	Passed	Unanimous

(3) Consider BAWN amendments

Table 402.1.1 SHG Requirements	Withdrawn	Amendment does not apply to Zone 5
Table 402.1.1 & 402.1.3 (Basement Wall R and U Value)	Withdrawn	Amendment does not apply to Zone 5
Table 402.1.1 & 402.1.3 (Wood Frame Wall Insulation)	Passed	Unanimous
402.2.2 Ceilings w/o attic spaces	Passed	Unanimous
403.2.2 Compliance testing	Tabled	BAWN was to rewrite, specifying amendment applies to housing tracts.
Table 405.5.2(1)	Tabled	ResCheck will not support this change. BAWN to rewrite and provide prescriptive table.

After a review of the proposed BAWN amendments it was determined that since the amendments are below code, DOE acting for the state may not accept them. Regardless of future acceptance from the state, the committee will act on the proposed amendments and forward to the state for review.

(4) Next meeting date

No date was set. Several amendments need to be rewritten and resubmitted. Chair will set meeting date.